

Village of Inverness - Water Works - Record of Operation 2026

6.4 gallons per 77 gallons (of 6% Javex) or 3.2 gallons per 77 gallons of water if using 12% Chlorine

Notes: *Test results in mg/L or ppm *Well water depth - depth in feet below top of Pitless Unit *Non-pumping deptn December, 2001 = 117.65 feet

Day	Time	Chlorine Usage (M³)	Raw Water Readings (M³)	Water Meter Readings (M³)	Volume (M³)	Tests		Well Water Depth (feet)		Tn max 1.0 NTU	Tn Raw	Iron max 0.12 mg/L	Iron Raw	MN max 0.12 mg/L	Well Hours	Read by
						CI Free	CI Total									
		7.98	354623	314270	303										3621.48	JCN
Forward Prev. Reading			0.0	0.0	0.0	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.000	0.00	
1/Aug/26	9:00 AM	9.00	354975	314630	360	1.35	1.54			0.12					3634.29	JCN
2/Aug/26	9:15 AM	8.92	355317	314962	332	1.34	1.58			0.10					3647.31	JCN
3/Aug/26	10:45 AM	7.12	355593	315239	277	1.29	1.50			0.11					3657.92	JCN
4/Aug/26	8:45 AM	5.55	355809	315465	226	1.36	1.50			0.09	0.25	0.02	0.51		3666.23	ICA
5/Aug/26	8:00	6.14	356047	315707	242	1.32	1.47			0.10					3675.40	LIDW
6/Aug/26	7:00	5.73	356264	315914	207	1.34	1.45			0.12					3684.10	LIDW
7/Aug/26	7:00	5.61	356499	316157	243	1.17	1.46			0.12	0.47	0.02	0.57	---	3692.80	LIDW
8/Aug/26	9:00	9.05	356832	316485	328	1.35	1.52			0.13					3706.30	LIDW
9/Aug/26	10:30	7.86	357136	316796	311	1.27	1.42			0.11					3718.20	LIDW
10/Aug/26	6:45	11.00	357259	316914	118	0.57	0.79			0.13	0.35	0.04	0.50	0.50	3721.50	LIDW
11/Aug/26	8:15	1.39	357316	317075	161	1.12	1.30			0.13					3725.70	LIDW
12/Aug/26	7:30	3.60	357458	317220	145	0.71	0.91			0.12		0.03		---	3731.40	LIDW
13/Aug/26	7:00	0.0	357459	317370	150	0.80	0.94			0.12					3731.40	LIDW
14/Aug/26	6:30 AM	12.51	357929	317596	226	1.03	1.50			0.16					3750.11	ICA
15/Aug/26	9:15 AM	5.22	358128	317795	199	1.27	1.43			0.08					3758.22	ICA
16/Aug/26	11:50	7.49	358420	318091	296	1.29	1.47			0.11					3769.23	ICA
17/Aug/26	6:30 AM	5.50	358631	318286	195	1.30	1.49			0.11					3777.23	ICA
18/Aug/26	7:30 AM	4.36	358801	318455	169	1.26	1.42			0.15		0.02			3783.84	ICA
19/Aug/26	7:50 AM	5.00	358992	318651	196	1.31	1.42			0.08					3791.15	ICA
20/Aug/26	7:50 AM	6.17	359254	318864	213	1.25	1.49	117.2		0.14					3801.36	JCN
21/Aug/26	8:00 AM	8.63	359586	319191	327	1.37	1.53			0.09	0.35	0.04	0.38	0.017	3813.97	JCN
22/Aug/26	8:45 AM	4.74	359770	319373	182	1.31	1.49			0.09					3820.98	JCN
23/Aug/26	10:15 AM	9.22	360188	319716	343	1.33	1.55			0.09					3834.19	JCN
24/Aug/26	7:30 AM	5.73	360352	319928	212	1.37	1.58			0.07					3842.50	JCN
25/Aug/26	8:45 AM	4.92	360542	320112	184	1.24	1.46			0.09	0.33	0.02	0.35	0.016	3849.81	JCN
26/Aug/26	10:30 AM	5.59	360760	320326	214	1.20	1.46			0.08					3858.11	JCN
27/Aug/26	8:00 AM	4.78	360946	320504	178	1.23	1.52			0.07					3865.12	JCN
28/Aug/26	7:00 AM	6.37	361192	320749	245	1.40	1.61			0.07					3874.23	ICA
29/Aug/26	9:40 AM	7.39	361481	321025	276	1.44	1.61			0.08					3885.04	ICA
30/Aug/26	11:20 AM	5.99	361713	321241	216	1.48	1.68			0.11					3893.75	ICA
31/Aug/26	7:40 AM	2.81	361822	321353	112	1.38	1.53			0.10		0.03			3897.95	ICA
TOTALS		0.00	-	-	-	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.000	-	
MIN VALUE		0.00	-	-	-	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.000	-	CAO Signature
MAX VALUE		0.00	-	-	-	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.000	-	
AVG VALUE		#DIV/0!	#DIV/0!	#DIV/0!	-	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	Mayor Signature