



October 4, 2024

Village of Buena Vista  
1050 Grand Avenue  
Buena Vista, SK S0G 4C0

Attention Waterworks Owner/Operator:

**RE: Rescinding Precautionary Drinking Water Advisory – Village of Buena Vista**

The Water Security Agency, in consultation with the Saskatchewan Health Authority-Regina Office, is advising that the ***“Precautionary Drinking Water Advisory” (PDWA)*** issued for the following portion of the Village of Buena Vista’s distribution system has been rescinded immediately **October 4, 2024**.

**Buena Vista Bay**

The rescinding of the PDWA was based upon information provided by your community, which included:

- The leak repair is completed, and the affected portion has been disinfected and flushed to applicable standards.
- Chlorine residuals and turbidity throughout the WTP and distribution system are within regulatory requirements; and
- Bacteriological sampling is within regulatory limits.

Your community may return to normal monitoring requirements as identified in your permits monitoring schedule.

In closing, I would like to acknowledge that the Water Security Agency appreciates the efforts and cooperation demonstrated by staff at your water treatment plant, as well as officials of the Village of Buena Vista in addressing the advisory.

For further information please do not hesitate to contact the undersigned at 306.527.6128 or [jeff.hindle@wsask.ca](mailto:jeff.hindle@wsask.ca).

Sincerely,

A handwritten signature in black ink, appearing to read "J. Hindle", written over a horizontal line.

Jeff Hindle A.Sc.T.  
Environment Officer  
Water Security Agency

cc: Derrick Hoehn, Water Advisories - Water Security Agency  
Saskatchewan Health Authority – Regina Office