

November 25, 2025

306-527-6128

Via Email: admin@buenavista.ca

Village of Buena Vista
1050 Grand Avenue
Buena Vista SK S2V 1A2

Attention Waterworks Owner/Operator:

RE: Precautionary Drinking Water Advisory for *the Village of Buena Vista*: - Rescinded

The Water Security Agency, in consultation with Saskatchewan Health Authority is advising that the “Precautionary Drinking Water Advisory” (PDWA) issued by the Water Security Agency for the *Village of Buena Vista*’s water distribution system has been rescinded, effective immediately.

The rescinding of the PDWA was based upon information provided by your operational staff, which included:

- The receipt of two consecutive sets of three (6 total) bacteriological samples collected 24 hours apart from the water distribution system are negative for bacteriological growth.

You may return to normal water quality monitoring requirements as detailed in your Permit to Operate a Waterworks. Thank you for your cooperation during this event. For further information please contact the undersigned at 306-527-6128 or jeff.hindle@wsask.ca.

Sincerely,



Jeff Hindle,
Environment Officer
Water Security Agency

cc: Don Turner - Manager, Compliance Promotion South, WSA (email)
Water Advisories, Water Security Agency
Saskatchewan Health Authority, Regina Office